

# APPENDIX B STANDARD DETAILS



## RESIDENTIAL WATER METER INSTALLATION




KENT COUNTY WATER AUTHORITY

KCWA 'proudly serving'

# RESIDENTIAL WATER METER


NOT TO SCALE



KCWA 'proudly serving'

METER PIT NUNLUAD RATED

NOT TO SCALE




NOTES:

- ALL PIPE, FITTINGS AND APPURTENANCES SHALL BE LINED WITH NSF APPROVED COATINGS OR NON LEAD BRASS OR STAINLESS STEEL.
- METER AND BACKFLOW TO BE LOCATED IN A HEATED SPACE WITH UNOBSTRUCTED ACCESS FOR MAINTENANCE, REPAIR AND TESTING.

- AND TESTING.
  METER, BACKFLOW AND ALL APPURTENANCES TO BE PURCHASED AND INSTALLED BY PROPERTY OWNER.
  ALL COMPONENTS MUST MEET KENT COUNTY WATER AUTHORITY MATERIAL REQUIREMENTS.
  DOMESTIC BYPASS IS AT THE OPTION OF THE OWNER TO INSTALL.
  TEST PORT SPOOL PIECE REQUIRED FOR MACH 10 METER INSTALLATION.
  VICTAULIC CONNECTIONS MAY BE USED AFTER THE METER UPON APPROVAL BY KENT COUNTY WATER AUTHORITY. THE
  COATINGS MUST BE NSF APPROVED FOR DRINKING WATER.
  BACKFLOW PREVENTERS FITTED WITH BUTTERFLY VALVES MAY BE USED IN LIEU OF OS&Y VALVES.

**KCWA** "proudly serving" KENT COUNTY WATER AUTHORITY ABOVE GRADE FIRE & DOMESTIC INSTALLATION NOT TO SCALE






KENT COUNTY WATER AUTHORITY

DEDUCT METER INSTALLATION

HOMEOWNERS RESPONSIBILITY

NOT TO SCALE



#### NOTES:


1. ROADWAY RESTORATION IN ACCORDANCE WITH COMMUNITY OR RIDOT.

KENT COUNTY WATER AUTHORITY

# KCWA TRENCH INSTALLATION IN ROCK AND SOIL

'proudly serving'

NOT TO SCALE



#### NOTE


- 1.) SERVICE MATERIALS PER KCWA SPECIFICATION UNLESS CITY OR TOWN CODES REQUIRE SPECIFIC MATERIALS THAT HAVE BEEN APPROVED BY KCWA.
- 2.) SERVICE LINE FROM CURB BOX TO BUILDING SHALL BE INSPECTED, TESTED AND APPROVED BY THE LOCAL PLUMBING INSPECTOR.

KENT COUNTY WATER AUTHORITY



SERVICE CONNECTION

NOT TO SCALE



NOTE: 1. MATERIALS PER KCWA REGULATIONS


KCWA proudly serving


KENT COUNTY WATER AUTHORITY

SERVICE CONNECTION

GREATER THAN 4 INCHES

NOT TO SCALE






KCWA proudly serving

KENT COUNTY WATER AUTHORITY

# PERMANENT BLOWOFF ASSEMBLY

NOT TO SCALE




KENT COUNTY WATER AUTHORITY

KCWA 'proudly serving'

AUTOMATIC AIR RELEASE MANHOLE

NOT TO SCALE




KCWA 'proudly serving'

KENT COUNTY WATER AUTHORITY

**HYDRANT** 

NOT TO SCALE



#### NOTE:


1.) TAPPING SLEEVE AND VALVE TO BE SWABBED WITH CHLORINE SOLUTION.

KCWA proudly serving'

KENT COUNTY WATER AUTHORITY

TAPPING SLEEVE AND VALVE

NOT TO SCALE




AFTER THE COMPLETION OF THE FINAL FLUSHING THE CONTRACTOR SHALL REMOVE THE TEMPORARY FLUSHING CONNECTION AND CONNECT THE
NEW WATER TO THE EXIST. WATER MAIN
ALL PIPING AND FITTING SHALL BE DISINFECTED
TO THE SATISFACTION OF THE KCWA.

KENT COUNTY WATER AUTHORITY



TEMPORARY FLUSHING CONNECTION

NOT TO SCALE



AFTER THE COMPLETION OF THE FINAL FLUSHING THE CONTRACTOR SHALL REMOVE THE TEMPORARY FLUSHING CONNECTION AND INSTALL A CAP WITH MEGALUGS AND A THRUST BLOCK





KENT COUNTY WATER AUTHORITY

TEMPORARY FLUSHING CONNECTION

ON DEAD END WATER MAIN

NOT TO SCALE






- \* TRANSITION COUPLING, DRESSER STYLE, TO BE USED ONLY WHEN EXISTING WATER MAIN IS OF DIFFERENT MATERIAL OTHER THAN DUCTILE IRON.
- \* SOLID SLEEVE TO BE RESTRAINED WITH APPROVED RESTRAINT FITTINGS
- \* ONLY TO BE USED WHEN CALCULATED FRICTION LOSS WILL NOT ADVERSELY EFFECT DISTRIBUTION PRESSURE AND FLOW
- \*\* MINIMUM DEPTH OF COVER SHALL BE 2'-0". THE WATER PIPE SHALL BE CLASS 54 AND INSULATED WITH 2" FOAMGLASS INSULATION W/ PITT WRAP OR EQUAL WHERE THE WATER PIPE HAS LESS THAN 5' OF COVER

KCWA proudly serving'


WATER MAIN HURIZUNTAL UR
VERTICAL RELUCATION

NOT TO SCALE



#### NOTES:

- 1. THE VERTICAL SEPARATION BETWEEN THE WATER MAIN AND THE PROPOSED UTILITY SHALL BE A MINIMUM OF 18 INCHES.
- 2. THE HORIZONTAL SEPARATION BETWEEN THE WATER MAIN AND THE PROPOSED UTILITY SHALL BE A MINIMUM OF 10 FEET.
- 3. IF 1 OR 2 CANNOT BE MAINTAINED THE PROPOSED UTILITY SHALL BE INSTALLED WITHIN A CARRIER PIPE UPON WRITTEN APPROVAL BY THE KCWA.
- 4. SEWER MAIN AND SERVICES ARE NOT ALLOWED TO CROSS OVER THE TOP OF WATER MAIN.
- 5. CONCRETE ENCASEMENT IS NOT ALLOWED.




CARRIER PIPE DETAIL

KCWA proudly serving


KENT COUNTY WATER AUTHORITY

UTILITY SEPERATION

NOT TO SCALE



# TRENCH DETAIL




KCWA 'proudly serving'

WATER SERVICE WITHIN 25 FT.

OF CONTAMINATION SOURCE


NOT TO SCALE



# PRIOR TO CONNECTION

#### NOTE:

- 1. PRIOR TO FINAL APPROVAL FOR PERMANENT CONNECTION FROM KCWA, CONTRACTOR SHALL PERFORM.
  PRESSURE TESTING AND CHLORINATION.
  2. SLEEVE FOR CLOSURE TO BE SWABBED
- WITH CHLORINE SOLUTION.




CONNECTION

**KCWA** 'proudly serving'


KENT COUNTY WATER AUTHORITY CONNECTION OF NEW WATER MAIN TO EXISTING WATER MAIN

NOT TO SCALE



proudly serving\* KENT COUNTY WATER
TEMPURARY CUNNECTION
TESTING AND DISIN AUTHORITY FUR PRESSURE


NDT TO SCALE




GER PIPE 18" MIN SO OS OUNDISTURBED EARTH

BENDS & TEES SECTION

PLAN & ELEVATION PLUGS





PLAN TEES

#### NOTES:

- 1.> ALL CONCRETE SHALL BE 4000 P.S.I @ 28 DAYS.
- 2.) CONCRETE THRUST BLOCKS SHALL BEAR AGAINST UNDISTURBED EARTH.
- 3.) FORMS TO BE USED AS NECESSARY.
- 4.) ALL BOLTS AND NUTS TO BE PROTECTED FROM CONCRETE AND EASILY ACCESSIBLE WHEN THRUST BLOCK INSTALLED.
- 5.) REGISTERED PROFESSIONAL ENGINEER IN THE STATE OF R.I. SHALL VERIFY ALL CALCULATIONS DURING DESIGN TO MEET CONDITIONS OF PROJECT AND KCWA REQUIREMENTS.
- 6). IN LIEU OF POURED IN-PLACE CONCRETE THRUST BLOCKS,
  PRECAST CONCRETE THRUST BLOCKS WILL BE ALLOWED, MINIMUM SIZE 2'x2'x2'.
- 7.) IN ADDITION TO THRUST BLOCKS ALL FITTINGS SHALL HAVE MECHANICAL RESTRAINED JOINTS.

SIZE	TEES		PLUGS		90. BEND		45° BEND		555. BEND		11¼°BEND	
	Α	В	С	D	Α	В	Α	В	Α	В	Α	В
6"	20"	10"	10"	21"	24"	12"	18"	9"	13"	7"	9"	5"
8"	26"	13"	12"	26"	32"	16"	24"	12"	17"	9"	12"	6"
10"	34"	17"	14"	34"	40"	20"	30"	15"	22"	11"	15"	8"
12"	41"	20"	16"	41"	48"	24"	35"	18"	25"	13"	18"	9"
16"	54"	27"	20"	54"	64"	32"	47"	23"	34"	17"	24"	12°

KENT COUNTY WATER AUTHORITY



## THRUST BLOCK

"proudly serving"

NOT TO SCALE

#### RESTRAINED PIPE LENGTHS FOR RESTRAINED FITTINGS

#### **FITTING**

#### **RESTRAINED LENGTH**

12" DEAD END	55'					
12" x 12" TEE	44' (ON BRANCH)					
12" x 10" TEE	34' (ON BRANCH)					
12" x 8" TEE	23'					
12" x 6" TEE	9'					
12" 90°BEND	24'					
12" 45°BEND	10'					
12" 22-1/2°BEND	5'					
12" 11-1/4°BEND	3'					
12" x 8" REDUCER	29' (ON 12")					
12" x 6" REDUCER	40' (ON 12")					
12" x 4" REDUCER	48' (ON 12")					
8" DEAD END	39'					
8" x 8" TEE	28' (ON BRANCH)					
8" x 6" TEE	16' (ON BRANCH)					
8" 90°BEND	17'					
8" 45°BEND	7'					
8" 22-1/2°BEND	4'					
8" 11-1/4°BEND	2' (ON 8")					
8" x 6" REDUCER	17' (ON 8")					
8" x 4" REDUCER	28'					
6" DEAD END	39'					
6" x 6" TEE	19' (ON BRANCH)					
6" 90°BEND	13'					
6" 45°BEND	6'					
6" 22-1/2°BEND	3'					
6" 11-1/4°BEND	2'					
6" x 4" REDUCER	15' (ON 6")					

#### NOTE:

- ALL JOINTS, INCLUDING PIPE JOINTS, VALVE JOINTS, AND FITTING JOINTS, SHALL BE RESTRAINED WITHIN THE LIMITS OF RESTRAINED LENGTHS LISTED ON THIS TABLE. MECHANICAL JOINT PIPE AND MECHANICAL RESTRAINTS WILL BE IN ACCORDANCE WITH THE ABOVE TABLE.
- 2. THE TABLE SHOWS LENGTHS OF PIPES WHICH MUST BE RESTRAINED ON BOTH SIDES OF THE FITTING.
- 3. ALL DEAD END PIPE SHALL BE PROPERLY RESTRAINED PRIOR TO PRESSURE TESTING.
- 4. REGISTERED PROFESSIONAL ENGINEER IN THE STATE OF R.I. SHALL VERIFY ALL RESTRAINING CALCULATIONS & LENGTHS DURING DESIGN, MEETING ALL REQUIREMENTS OF THE KCWA.
- 5. THE RESTRAINED LENGTH FOR TEE IS ALONG THE BRANCH.
- 6. LENGTH TO BE RESTRAINED IS ON THE LARGE SIDE OF THE REDUCER.
- 7. IF THE REQUIRED RESTRAINED LENGTH IS NOT AVAILABLE A THRUST BLOCK SHALL BE INSTALLED.
- 8. RESTRAINED LENGTH SHALL INCORPORATE 2 TIMES SAFETY FACTOR.


KENT COUNTY WATER AUTHORITY



RESTRAINED PIPE LENGTHS

NOT TO SCALE

EXAMPLE OF LOCATION OF VALVES, FITTINGS AND HYDRANTS FOR AS-BUILT DRAWINGS




KCWA 'proudly serving'

KENT COUNTY WATER AUTHORITY

AS-BUILT EXAMPLE FOR WATER MAINS

NOT TO SCALE

# EXAMPLE OF HOUSE SERVICE AS- BUILTS




DEPTH OF MAIN = 5' STANDARD SIZE OF SERVICE = 3/4"

KENT COUNTY WATER AUTHORITY

## AS-BUILT EXAMPLE FOR WATER SERVICE

NOT TO SCALE




#### NOTES:

- NOTES:

  1. PROVIDE MAKE-UP OR SPOOL PIECES AS REQUIRED.
  2. PROVIDE ACCESS AND BLOWOUT PANELS AS REQUIRED.
  3. DESIGN FOR FROST AND FREEZING PROTECTION.
  4. PROVIDE LIGHTING AND TEMPERATURE ALARM.
  5. LOCATE ENCLOSURE AT SERVICE CONNECTION ENTRANCE.
  6. LOCATE IN AN ELEVATED AREA NOT PRONE TO FLOODING.
  7. PROVIDE LOCK AND CHAIN FOR VALVE ON BYPASS.



KENT COUNTY WATER AUTHORITY ABOVE GRADE MASTER METER INSTALLATION NOT TO SCALE



proudly serving

CRUSSING NOT TO SCALE